



Installation Instructions



Important Preinstallation Note: 4" square welded junction box (30 cu. in. volume) supplied by others. Canopies and suspensions are ordered separately. **Junction boxes should be installed regressed 3/16" into sheetrock ceiling. For T-bar ceilings use caddy clips by others.** Please refer to the approved layout drawings prior to installation, if applicable.

VIVO MEDIUM
for
TECTON SYSTEM

DO NOT REMOVE THE LED ASSEMBLY. THIS WILL VOID THE WARRANTY. Call Zumtobel at 1-800-448-4131 for questions.



DANGER

RISK OF FIRE AND ELECTRICAL SHOCK

Contact, improper installation, or improper servicing MAY RESULT IN DEATH OR SERIOUS INJURY!

Fixture must be installed by a qualified electrician only. Fixture is intended for installation in accordance with the National Electrical Code, local and federal code specifications. Disconnect power at electrical panel before servicing. Retain these instructions for maintenance reference.



12 Install TECTON Head to trunking by attaching head batten. Trunking is polarized allowing for installation in one direction only. Rotate the CLIX handle to lock the batten to the trunking.

